



BEST INC. LIMITED

ROOMS 1318-20, 13/F, HOLLYWOOD PLAZA, 610 NATHAN ROAD, MONGKOK, KOWLOON, HONGKONG

CERTIFICATE OF ANALYSIS

R134A

To: MIDBOURG INVESTMENT LDA
AV. PEDRO CASTRO VAN DUNEM LOY,
S/N, LUANDA, ANGOLA

Invoice No.: 20180525
Date: JUL.09,2018

By Vessel: MSC MARGRIT FY827A
From: NINGBO, CHINA

Sales Contract No.: BEST20180525
To: LUANDA, ANGOLA

PRODUCT NAME: REFRIGERANT GAS
200 CYLINDERS R134A
10 CARTONS(200 CANS) R134A
QUANTITY: 210 PCS

SAMPLE DATE: 20180706
INSPECTION DATE: 20180706
EXPIRE DATE: 20190705
PRODUCTION LOT NUMBER: 20180706

WE HERE BY CERTIFY THAT THE ABOVE PRODUCT WAS TESTED AND FOLLOWING RESULTS HAVE BEEN OBTAINED.

TEST ITEMS	SPEC.	RESULTS
Appearance	Bright & Clear Liquid.	Bright & Clear Liquid.
Purity (% by weight)	99.90 min	99.96
Water (% by weight)	0.0010 max.	0.0001
Acidity (% by weight)	0.0001 max.	NONE
Non Condensables (% by volume)	1.0 max	0.31
High Boiling Residue (% by weight)	0.0100 max.	0.01
Chloride (pass/fail)	pass	pass
Total Chlorofluoro Unsaturates (% by weight)	0.0040 max	0.001

CONCLUSION: CONFORMITY.