



BEST INC. LIMITED

ROOMS 1318-20, 13/F, HOLLYWOOD PLAZA, 610 NATHAN ROAD, MONGKOK, KOWLOON, HONGKONG

CERTIFICATE OF ANALYSIS

R22

To: MIDBOURG INVESTMENT LDA
AV. PEDRO CASTRO VAN DUNEM LOY,
S/N, LUANDA, ANGOLA

Invoice No.: 20180525
Date: JUL.09,2018

By Vessel: MSC MARGRIT FY827A
From: NINGBO, CHINA

Sales Contract No.: BEST20180525
To: LUANDA, ANGOLA

PRODUCT NAME: REFRIGERANT GAS
350 CYLINDERS R22
10 CARTONS(200 CANS) R22
QUANTITY: 360 PCS

SAMPLE DATE: 20180706
INSPECTION DATE: 20180706
EXPIRE DATE: 20190705
PRODUCTION LOT NUMBER: 20180706

WE HERE BY CERTIFY THAT THE ABOVE PRODUCT WAS TESTED AND FOLLOWING RESULTS HAVE BEEN OBTAINED.

TEST ITEMS	SPEC.	RESULTS
Purity (%)	≥99.9	99.93
Isomer Content Isomer (% by weight)	N/A	Pass N/A
Air and Other Non Condensables (% by volume@25.0°C)	≤1.5	0.05
Water (ppm by weight)	≤10	7.3
All Other Volatile Impurities (% by weight)	≤0.5	0.019
High Boiling Residue (% by volume)	≤0.01	0.001
Particulates/Solids	Visually clean to pass	Pass
Acidity(as HCl) (ppm by weight)	≤1.0	Pass Undetected
Chloride	No visible Turbidity	Pass

CONCLUSION: CONFORMITY.